



Certificate of Compliance

Certificate: 1358188

Master Contract: 237484

Project: 2721544

Date Issued: July 24, 2014

Issued to: Automation Products Group Inc

1025 West 1700 North
Logan, UT 84321
USA
Attention: Karl Reid

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Virali Shah

Issued by: Virali Shah

PRODUCTS

CLASS 3211 86 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers -
Miscellaneous-Certified to U.S. Standards

CLASS 3211 06 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers -
Miscellaneous

Float switches Model No. KA-C, KA-M and KA-S Series:

Rated 250 Vac, 6 A max (resistive), 3 A max (inductive) or 250 V dc, 0.3 A max.

Note: These devices are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by CSA.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 14-13 - Industrial Control Equipment

ANSI/UL 508 (17th Edition) - Industrial Control Equipment