



# Certificate of Compliance

**Certificate:** 1358188

**Master Contract:** 237484

**Project:** 2721544

**Date Issued:** July 24, 2014

**Issued to:** Automation Products Group Inc

1025 West 1700 North  
Logan, UT 84321  
USA  
Attention: Karl Reid

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Virali Shah*

**Issued by:** Virali Shah

## **PRODUCTS**

**CLASS 3211 86** - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers -  
Miscellaneous-Certified to U.S. Standards

**CLASS 3211 06** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers -  
Miscellaneous

Float switches Model No. KA-C, KA-M and KA-S Series:

Rated 250 Vac, 6 A max (resistive), 3 A max (inductive) or 250 V dc, 0.3 A max.

Note: These devices are Certified as components for use only in other Certified equipment where the suitability of the combination is determined by CSA.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No 14-13 - Industrial Control Equipment

ANSI/UL 508 (17th Edition) - Industrial Control Equipment